

PLC will present unacceptable levels of interference to current users of the HF spectrum. The LV power distribution systems in the USA were not designed to carry RF without radiation. Recent tests in Japan, whose MV distribution is similar to ours, revealed significant interference problems. For more information on Japanese and European studies on PLC, please look at the information contained in following link: www.arrl.org/tis/info/HTML/plc

Thank you,

Marc Tarplee